





CHPE LLC
623 Fifth Avenue, 20th Floor
New York, NY 10022



Segment 8 (Package 5A)
EM&CP Appendix E New Sheets

CHPE EM& CP

Schenectady and Albany County,
New York

Deviation Zone Analysis

- Mile Post
- Segment 8 Trench Excursion
- - Segment 8 HDD Excursion
- Segment 8 Trench
- - Segment 8 HDD
- Segment 8
(Previous Alignment)
- ▨ Delineated Wetlands
- ▨ Delineated Streams
- ▭ Deviation Zone





Prepared March 1, 2024
Basemap: Esri "World Imagery" map service



CHPE EM& CP
Schenectady and Albany County,
New York

Deviation Zone Analysis

- Mile Post
- Segment 8 Trench Excursion
- - Segment 8 HDD Excursion
- - Segment 8 Trench
- - Segment 8 HDD
- Segment 8 (Previous Alignment)
- ▨ Delineated Wetlands
- ▨ Delineated Streams
- ▭ Deviation Zone



Prepared March 1, 2024
Basemap: Esri "World Imagery" map service



CHPE LLC
623 Fifth Avenue, 20th Floor
New York, NY 10022

Segment 8 (Package 5A)
EM&CP Appendix J Memo

April 1, 2024
File No. 322004-000

Kiewit Engineering (NY) Corporation
470 Chestnut Ridge Rd, 2nd Floor
Woodcliff Lake, NJ 07677

Attention: Jason Neff, PE, PMP - Design Engineering Manager

Subject: HDD 73A,74 Design Revisions
Champlain Hudson Power Express – Segment 5b
Rotterdam to Fuera Bush, NY

Dear Mr. Neff:

At your request, we have modified HDD 73A,74 to accommodate minor alignment modifications. Specifically, these modifications include reversal of the drilling direction and shifting of the HDD entry and exit pits. Amended text and design calculations are attached. The following is noted:

- The duct pull forces have not changed significantly; and
- The risk of IR increases at the drill exit, as the revised geometry involves drilling downslope. The driller will also need to be prepared to contain the drill fluid which will flow downhill to the exit pit during drilling.

The discussions and recommendations contained in the IFC HDD Basis of Design Report and IRR plan otherwise remain unchanged.

We thank you for this opportunity to be of service to you and your team on this project. Should you have any questions or require additional information, please do not hesitate to contact the undersigned at your convenience.

Sincerely,

Brierley Associates Underground Engineers, PLLC



Nick Strater, P.G.
Trenchless Design Manager



Brian C. Dorwart, P.E., P.G.
Sr. Consultant

1.0 Introduction

Table 1: HDD Locations, Lengths, and Description

HDD #	Approx. Start Station*	Approx. End Station*	Approx. HDD Length, ft	Obstruction Crossed
73A,74	50100+00	50120+04	2,004	NYS Thruway (I-90)

*Project stationing shown is approximate. Each HDD has its own independent stationing.

4.1 Surface Conditions

HDD #73A,74

HDD #73A,74 pass below an overhead electric cable easement (Niagara Mohawk) which is oriented approximately northwest-south, and about 100-ft wide. Power poles are located to the west of the HDD alignments.

The HDD #73A,74 alignments also pass below Interstate I-90 which is oriented approximately southeast-northwest, 115-ft wide, and located on an elevated embankment. Interstate I-90 passes over two (2) active CSX rails to the immediate east by means of a concrete deck bridge. The western bridge abutment is located to the immediate east of the HDD alignments. The areas to the north of I-90 and adjacent to Niagara Mohawk easements are heavily wooded.

The HDD #73A,74 exit (southeast) is located in a paved cul-de-sac at the northeast end of S Westcott Rd. The HDD #73A,74 entry (northwest) is located in a wooded area to the northwest of the Niagara Mohawk easement. The CSX rails are located approximately at-grade to the east-northeast, and are oriented northwest-southeast. The CSX rails rest on an elevated embankment which is approximately 4 to 5 feet higher than adjacent grades. Portions of the HDD #73A,74 alignments are located within the CSX right-of-way.

The surface grades in the site vicinity generally slope downward to the south, from about El. 326 to El. 314. The surface of I-90 is at about El. 350.

APPENDIX B
HDD Calculations Per Crossing

HORIZONTAL DIRECTIONAL DRILL DESIGN

PROJECT: Champlain Hudson Power Express
Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem
Schenectady County, NY

CROSSING: HDD 73A-74 Conduit #1
NY State Thruway(I-90)

ISSUE: Issued for Construction (IFC)

Contents:

Table 1	DESIGN SUMMARY, ASSUMPTIONS, CONDITIONS
Table 2	DRILL PATH DESIGN CALCULATIONS
Table 3	ANTICIPATED PULLING FORCE - SINGLE CONDUIT
Table 4	PLASTIC STRESS
Figure 1	APC AND FPC CURVES AND ASSUMED GEOLOGIC SECTION

Prepared For: Kiewit

Prepared By: Brierley Associates
167 S. River Road, Suite 8
Bedford, NH 03110
603.206.5775 (O)

Project No: 322004-000
Print Date: 1-Apr-2024



DATE	REV	DESCRIPTION	BY
10/23/2022	0	Design Submittal	ABL
3/23/2023	1	Issued for Construction	ABL
8/29/2023	2	Profile Revisions	KRF
3?31/24	3	Plan Revisions	NHS

DRILL PATH DESIGN CALCULATIONS

Entry Station	0+00.00	FT	*If no water or mudline then use lower of entry or exit elevation
Exit Station	20+45.21	FT	
Entry and Exit Design Coordinates & Elevations (Ft) (Note 2)			
	East	North	
Entry	629021.1198	1437814.4763	326.40 ft
			</

SUMMARY HORIZONTAL CURVE CALCULATIONS											
Start				End				Length	Radius	Angle	
Station	Easting	Northing		Station	Easting	Northing	Azimuth				
Tangent	0+00.00	629021.1198	1437814.4763	13+15.88	629461.8497	1436574.5977	E 160.43163 N	1315.88	900.00	-21.962 deg.	
Curve	13+15.88	629461.8497	1436574.5977	16+60.86	629636.1280	1436279.3164	E 138.46925 N	344.98			
Tangent	16+60.86	629636.1280	1436279.3164	20+45.21	629890.9574	1435991.5954	E 138.46925 N	384.35			

HORIZONTAL PLAN CALCULATIONS (FT)			
Entry Tangent Segment	Horizontal Curve Segment	Exit Tangent Segment	
Plan Length, ft.	1315.88	Plan Length, ft.	384.35
Entry Azimuth, deg.°	N 160.43163 E	Exit Azimuth, deg.°	N 138.46925 E
Entry Azimuth, rad.°	2.80006	Exit Azimuth, rad.°	2.41674
Calculate PCH		Calculate Exit	Check Delta 0.0000 0.0000 OK CALC
PCH Easting	629461.8497	Easting	629890.9574
PCH Northing	1436574.5977	Northing	1435991.5954
Chord Length, ft.		Chord Length, ft.	342.88
Arc Length, ft.		Arc Length, ft.	344.98
Chord Azimuth, deg		Chord Azimuth, deg	149.4504
PI Easting =		PI Easting =	629520.3407
PI Northing =		PI Northing =	1436410.0486
PTH Easting =		PTH Easting =	629636.1280
PTH Northing =		PTH Northing =	1436279.3164
Cum Plan Length	1315.88	Cum Plan Length	1660.86
Cum Plan Length	1660.86	Cum Plan Length	2045.210223
			Exit Station 20+45.21 OK STA

Pull Geometry						
Pipe Entry	Exit	Enter the pipe entry location into the hole: Entry/Exit				
		Elevations		Vertical Angle		
Segment	Start	End	Start	End	Δ Angle	Path Length
Entry Tangent	311.00 ft	291.47 ft	-9.90 deg	-9.90 deg	0.00 deg	113.60 ft
Entry Curve	291.47 ft	273.60 ft	-9.90 deg	0.00 deg	9.90 deg	207.35 ft
Bottom Tangent	273.60 ft	273.60 ft	0.00 deg	0.00 deg	0.00 deg	1352.46 ft
Exit Curve	273.60 ft	299.82 ft	0.00 deg	12.00 deg	12.00 deg	251.33 ft
Exit Tangent	299.82 ft	326.40 ft	12.00 deg	12.00 deg	0.00 deg	127.83 ft
Total Check =						2052.56 ft
						OK
Compound Curve Assessment						
Start	Vert. Plan	Horiz. Plan				
Entry	374.53	1315.88	No, Horiz > Entry V(Tan+Curve)			
Exit	318.22	384.35	No, Horiz > Entry V(Tan+Curve)			

VERTICLE PATH DESIGN CALCULATIONS (FT)


Entry Tangent Segment 1		Entry Vert. Curve Segment 2		Middle Tangent Segment 3		Exit Vert. Curve Segment 4		Exit Tangent Segment 5	
Entry Angle	-12.000 deg.	Vertical Radius	1200.00	End Vert Angle	0.000 deg.	Radius	1200.00	Exit Elevation	311.00
		Vert. Curve, deg.	12.000 deg.	Inclined Bottom Tan	NO	Angle Change	9.900 deg.	Design Exit Angle	9.90 deg
Calculate Vertical PCV		Calculate Vertical PTV		Calculate Vertical PCV		Calculate Vertical PTV		Calculate Exit	
Plan Length	125.036 ft	Plan Length	249.494 ft	Plan Length	1,352.45707 ft	Plan Length	206.315 ft	Plan Length	111.909 ft
Rod Length	127.829 ft	Arc Rod Length	251.327 ft	Rod Length	1,352.45707 ft	Arc Rod Length	207.345 ft	Rod Length	113.600 ft
Vertical Depth	-26.577 ft	Curve Δ Vert Depth	-26.223 ft	Vertical Depth	0.00000 ft	Curve Δ Vert Depth	17.869 ft	Vertical Depth	19.531 ft
		Lowest Elevation	273.600 ft			Lowest Elevation	273.600 ft	CK Total Cum Depth	-15.400 ft
Start Elevation	326.400 ft	Start Elevation	299.823 ft	Start Elevation	273.600 ft	Start Elevation	273.600 ft	Start Elevation	291.469 ft
End Elevation	299.823 ft	End Elevation	273.600 ft	End Elevation	273.600 ft	End Elevation	291.469 ft	Ck Exit Elevation	
End Vert Angle	-12.000 deg	End Vert Angle	0.000 deg	End Vert Angle	0.000 deg	End Vert Angle	9.900 deg	Prop. Plan Length	2045.210223

SUMMARY VERTICLE CURVE CALCULATIONS					
Start Station	0+00.00	Start Station	1+25.04	Start Station	3+74.53
PVC Station	1+25.04	PTV Station	3+74.53	PCV Station	17+26.99
Cum Plan Length	125.04	Cum Plan Length	374.53	Cum Plan Length	1726.99 ft
Cum Rod Length	127.83	Cum Rod Length	379.16	Cum Rod Length	1731.61 ft
Cum Depth	-26.58	Cum Depth	-52.80	Cum Depth	-34.9312

Summary of Drill Calculations	
Entry to Exit Elevation Change =	-15.40 ft
Minimum Design Elevation =	273.60 ft
Invert Depth below exit =	37.40 ft
Invert Depth below entry =	52.80 ft
Path Length =	2,052.56 ft
Plan Length =	2,045.21 ft
Minimum Plan Length (No Tangent) =	692.75 ft
Entry Angle =	-12.00 deg
Exit Angle =	9.90 deg
Compound Curve at Entry =	NO
Compound Curve at Exit =	NO

NOTES:

- Sign convention for angles - positive (+) angles are counterclockwise.
Due East is defined as 0 degrees.
- NAD83 New York State Plane East Zone
- Elevations are referenced to NAVD88 Datum
- All calculation locations represent the center of the drill hole.



Indicates inputs

Indicates status on internal design checks

ISSUE:

BRIERLEY ASSOCIATES
Limited Liability Company

"Creating Space Underground"

Brierley Associates
167 S. River Road, Suite 8
Bedford, NH 03110

Indicates inputs

Indicates status on internal design checks

Issued for Construction (IFC)

Champlain Hudson Power Express
Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem
Schenectady County, NY

TABLE 2
DRILL PATH DESIGN CALCULATION
HDD 73A-74 Conduit #1
NY State Thruway(I-90)

Revision 3

TBD

Pull Geometry

Lengths (Path)		Angles		Radius, R
L1 =	100.0 ft	Overbend	deg	300.0 ft
L2 =	113.6 ft	$\alpha =$	-9.9 °	-0.1728
L3 =	207.3 ft			1,200.0 ft
L4 =	1352.5 ft	$\chi =$	0.0 °	0.0000
L5 =	251.3 ft			1,200.0 ft
L6 =	127.8 ft	$\beta =$	12.0 °	0.2094
LT =	2152.6 ft			

INPUT: Assumed Friction Factors

$\mu_G =$	0.10	dry + rollers
$\mu_b =$	0.25	drill fluid in hole
$\mu_c =$	0.30	in hole no fluid

INPUT: Assumed Hydrokinetic Drag

$\tau_f =$	0.005 psi	Drill Fluid Shear Stress
------------	-----------	--------------------------

INPUT: Pipe Properties

Material	HDPE	IPS
Safe Pull Max. Stress, σ_{PM}	1,150 psi	PPI Table 1 12hr @ 73Deg F
Pipe/Bundle Diam.	14.25	BUNDLE PIPE/BUNDLE
Material Density, γ	59.28 pcf	
Outside Diameter, D_{OD}	14.25	Pipe or Bundle
Pipe Dry Weight, W_p	17.36 lb/ft	Pipe or Bundle
Min. Wall Thickness, t_m	1.194 in	For design installation pull stress
$DR = D_{OD}/t_{min}$	9	D_{OD} Stress 10.75 inches
Avg. Inside Diameter, D_{IA}	BUNDLE	Bundle Multiplier F_D 0.9042
12 Hr Pullback Modulus, E_T	65,000 psi	@T = 73 deg F
Poisson Ratio, μ	0.45	
Ovality Factor, f_o	0.84	2%
Buckling Safety, N	2.5	
Hydrostatic Design Stress, HDS	1,000 psi	HDB/2
Pressure Rating, $PR_{(80F)}$	250 psi	$PR = 2HDSF_T A_F / (DR \cdot 1) [F_T = 1]$

INPUT: Assumed Fluid Densities/Elevations

Ballast Density	62.4	pcf
Drill Fluid Density	78	pcf
Drill fluid elevation, H_F	310.00 ft	
Ballast Water El., H_W	310.00 ft	
Lowest Invert El., E_{Im}	273.60 ft	

Estimated for pull

Calculated Pipe and Fluid Properties


Pressure Pipe:	YES	
OD Perimeter Length, P	44.77 in	
Wall Section Area, A _W	41.68747289	
Volume Outside, V _{DO}	0.697 cf/LF	
Volume Inside, V _{DI}	0.408 cf/LF	
q _d =	2.69 lb/ft	Drill Fluid (unit drag)
ASTM EQ 18: Hydrokinetic, ΔT =	0.43 lb/ft	Comparison Only @ 8psi

Calculated Buoyant Forces

Pipe	Air Filled	Ballasted
On Ground, $w_a/w_{af} =$	17.36 Lb/LF	42.80 Lb/LF
In Hole with Drill Fluid, $w_b/w_{bf} =$	-37.01 Lb/LF	-11.58 Lb/LF

Pipe Entry Location - Drill Exit

(schematic, to show definition of variables only)



Calculated Pull Force							ASSESS	
POINT	Pull Force, F_D	Max Tensile Stress, σ_T	ASSESS $\sigma_T < \sigma_{PM}$	Pull Force, F_B	Max Tensile Stress, σ_T	ASSESS $\sigma_T < \sigma_{PM}$	$F_x < SPS$	
	No Ballast			Ballasted Pipe			Air	Ballast
A	3,802 lb	225 psi	OK	3,802 lb	225 psi	OK	OK	OK
B	4,689 lb	118 psi	OK	4,893 lb	123 psi	OK	OK	OK
C	6,413 lb	194 psi	OK	5,729 lb	177 psi	OK	OK	OK
D	12,688 lb	320 psi	OK	12,004 lb	303 psi	OK	OK	OK
E	18,031 lb	487 psi	OK	14,932 lb	409 psi	OK	OK	OK
F	19,348 lb	488 psi	OK	15,686 lb	396 psi	OK	OK	OK

ASSESS Pull Restricted Buckling Capacity, $P_{PA} > \Delta P$ invert

$P_{PA} = P_A F_R =$

93.96 psi

Ballasted OK

No Ballast OK

Maximum tensile stress during pullback = $\sigma_t = (F_T / \pi t_m (D_{OD} - t_m)) + E_T D_{OD} / 2R$

PPI Ch 12 Eq 16

Calculated Material Design Limits For Designed Drill Path

Safe Pull Strength, SPS	45,606 lb	$SSPS = \sigma_{PM} \pi D_{OD}^2 ((1/DR) - (1/DR'))$
Allowable Short Term Unconstrained Buckling, P_A	106.97 psi	$P_A = (2E_T / (1 - \mu^2)) (1 / (DR - 1))^2 (f_o / N)$
Maximum 12 hour Pull Stress Reduction, F_R	0.878323851	$F_R = (5.57 - (r + 1.09)^2)^{1/2} - 1.09$
$r =$	0.21219093	$r = \sigma_T / 2SPS$
Maximum applied pull Stress, σ_T	488 psi	From Pull Force Calculations
Ballasted Max. Differential Pressure on Pipe, ΔP_B invert	3.94	psi (-) indicates pipe is pressurized
Unballasted Max. Differential Pressure on Pipe, ΔP_U invert	19.72	psi (-) indicates pipe is pressurized

Calculated Drill Hole Diameter Assumed for Calculations

$D_H =$ 22

$D_O < 8"$ Use $D_H = D_O + 4"$; $8" < D_O < 24"$ Use $D_H = 1.5 \cdot D_O$; $D_O > 24"$ Use $D_H = D_O + 12"$

NOTES: 1 - Calculations were done in general accordance with ASTM F-1962 as modified to account for invert tangent section, independent vertical curves, and fluid drag. ASTM applies hydrokinetic pressure as shear per unit pipe length requiring a back calculation to determine actual pull force based on average pipe area.

ISSUE: Issued for Construction (IFC)

BRIERLEY ASSOCIATES Limited Liability Company "Creating Space Underground" Brierley Associates 167 S. River Road, Suite 8 Bedford, NH 03110	Champlain Hudson Power Express Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem Schenectady County, NY
	TABLE 3 - PULL ASSESSMENT ANTICIPATED PULLING FORCE - HDPE PULL HDD 73A-74 Conduit #1 NY State Thruway (I-90)
	Revision 3 TBD

TABLE 4

Pg 1 of 3

HDPE PROPERTIES

Champlain Hudson Power Express

Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem

Schenectady County, NY

HDD 73A-74 Conduit #1

NY State Thruway(I-90)

INPUTS

Pipe Material Properties

Sources: ASTM D3350 and Plastic Pipe Institute Publications and as referenced

Design Working Pressure, P _{WORK}	250 psi	Test Pressure, P _{TEST}	0 psig	At high point
Quantity of Pipes in Hole, Q =	1			
Pipe Material	PE4710	INPUT RESIN MATERIAL: PE3408, PE3608, PE4710		
ASTM D3350 Cell Classification	445574C	Design resin with minimum PENT test of 10,000 hours		
Standard Dimension	10			
Pipe measurement standard	IPS	IPS "Iron Pipe Size" of DIPS "Ductile Iron Pipe Size"		
DR = OD/Minimum Wall	9			
Outside Diameter, D _o =	10.750 in	Standard Manufacturer's Data Sheets		
Avg. Inside Diameter, D _i =	8.219 in	Standard Manufacturer's Data Sheets		
Minimum Wall, t _{min} =	1.194 in	Standard Manufacturer's Data Sheets		
Wall Section Area, A _W =	35.85681985	A _W = π*((D _o /2) ² -((D _o -2t)/2) ²)		
Unit OD Surface Area, in ² /LF, A _{OD} =	405.27 in ² /LF	A _{OD} = 12*π*D _{OD}		
Unit Outside Volume, V _{Do} =	0.630 cf/LF	V _{Do} = π*(D _o /2) ² /144		
Unit Inside Volume, V _{Di} =	0.368 cf/LF	V _{Di} = π*(D _i /2) ² /144		
HDB =	1,600 psi	Based on PPI Publication TR-4/2015 and ASTM 2837		
Design Factor for HDB, DF =	0.625	Based on PPI PE Handbook 2nd ED Chapter 5		
Hydrostatic Design Stress, HDS =	1000 psi	HDS = HDB*DF		
Environmental Factor, Af _e =	1	Reference 2: Use for pressure rating only		
Density =	59.28 pcf	1.410 g/cc	Average from WL Plastics WL122 for PE4710	
Weight Dry, W =	15.68	Lb/LF		
Tensile Yield, Ty psi =	3,500 psi	@73°F	Minimum from ASTM D3350 determined by ASTM D638	
Load Duration	Short Term	Long Term		
Duration Time	10 hours	50 yrs		
Design Temperature, °F	73 deg F	73 deg F	Assumed	
Design Ovality, %	2%	4%	See Sheets 4 of 5 for design ovality	
Factor of Safety, FS =	2.5	2.5	Industry Practice	
Modulus for given load duration, E =	65,000 psi	28,000 psi	Based on PPI Handbook Ch. 3 and WL Plastics WL118-0314	
Poisson Ratio, ν =	0.45	0.45	WL118: Use 0.35 if load duration is less than 12 hours	
Ovality factor f _o =	0.84	0.6	Reference 1: Based on Selected Design Ovality	
Temperature factor, f _t =	1.00	1.00	Source: WL Plastics WL118	

Project Fluids

Fluids	Pipe Internal Ballast	Expected External Fluid	Heavy External Fluid	Buoyant forces	
	Fresh Water	Drill Fluid 1	Drill Fluid 2	Dry Weight Pipe on ground, W_P	From MFG. Data Sheet
				Internal Ballast Weight, W_B	$W_B = V_{Di} * \gamma_{INT}$
	γ_{INT}	γ_{EXT1}	γ_{EXT2}	Expected Displaced Fluid Weight, W_{D1}	$W_{D1} = V_{Do} * \gamma_{EXT1}$
Density, γ	62.4	78	80	Heavy Displaced Fluid Weight, W_{D2}	$W_{D2} = V_{Do} * \gamma_{EXT2}$
	Buoyant Unballasted Fluid 1, B_{B1}	-33.48 lb/ft	$W_P - W_{D1}$		
	Buoyant Unballasted Fluid 2, B_{B2}	-34.74 lb/ft	$W_P - W_{D2}$		
	Ballasted on ground, B_G	38.67 lb/ft	$W_P + W_B$		
	Buoyant Ballasted in Fluid 1, BB_{B1}	-10.49 lb/ft	$B_G - W_{D1}$		
	Buoyant Ballasted in Fluid 2, BB_{B2}	-11.75 lb/ft	$B_G - W_{D2}$		

TABLE 4

Pg 2 of 3

HDPE PROPERTIES

Champlain Hudson Power Express

Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem

Schenectady County, NY

HDD 73A-74 Conduit #1

NY State Thruway(I-90)

1. ASSESS PIPE PRESSURE RATING

Failure mode: Short term = burst; Long term = slow crack growth

Short Term (<10 hours)

Design Temperature, °F =	73 deg F	
Ultimate Internal Pressure, P_U =	875 psi	$P_U = 2 \cdot T_y \cdot f_t / (DR-1)$
Allowable Internal Pressure, P_A =	400 psi	$P_A = 2 \cdot HDB \cdot f_t / (DR-1)$

ASSESSMENT TEST PRESSURE

OK

OK if $P_A \geq P_{TEST}$

Long Term Design for operating conditions

Design Temperature, °F =	73 deg F	
Pressure Rating, PR =	250 psi	$PR = 2 \cdot HDS \cdot f_t \cdot A_f / (DR-1)$
Maximum Occasional Surge, P_{OS} =	500 psi	$P_{OS} = 2 \cdot PR$
Maximum Reoccurring Surge, P_{RS} =	375 psi	$P_{RS} = 1.5 \cdot PR$

ASSESSMENT PRESSURE RATING

OK

OK if $PR \geq P_{WORK}$

2. ASSESS PIPE UNCONSTRAINED BUCKLING CAPACITY FOR CONSTRUCTION PRESSURES

CALCULATE: Unconstrained Buckling Capacity of pipe

Unconstrained buckling ASTM F1962 EQ 5

$$\text{Critical Pressure, } P_{CR} = f_o \cdot [2 \cdot E / (1 - \nu^2)] \cdot [(1 / (DR-1))^3]$$

	Short Term	Long Term
Design Temperature, F =	73 deg F	73 deg F
P_{CR} =	267.4 psi	82.3 psi
$P_a = P_{CR} / FS$	107.0 psi	32.9 psi

CALCULATE: internal and external pressure for deepest pipe invert depth and construction conditions

Critical unconstrained buckling pressure is at the pipe invert

Max. Depth to Invert 52.80 ft Ballast depth to invert, H_B 37.40 ft Drill Fluid depth to invert, H_{DF} 37.40 ftPipe Invert Internal Pressure, P_i

Air Ballast, P_A	0.00 psi
Full Ballast, $P_B = \gamma_{INT} \cdot (H_B + D_o / 24) / 144$	16.40 psi

Pipe Invert External Pressure, P_E

Drill Fluid 1, $P_{DF1} = \gamma_{EXT1} \cdot (H_{MDF} + D_o / 24) / 144$	20.50 psi
Drill Fluid 2, $P_{DF2} = \gamma_{EXT2} \cdot (H_{MDF} + D_o / 24) / 144$	21.03 psi
Water, $P_W = \gamma_{INT} \cdot (H_{DF} + D_o / 24) / 144$	16.40 psi

Unconstrained buckling occurs when DIFFERENTIAL PRESSURE between the inside pressure plus pipe capacity is less than the outside pressure. $(P_i + P_a) - P_E \leq 0$

Differential Pressures

	Short Term	Long Term	
Internal Air and External Fluid 1 = $(P_A + P_a) - P_{DF1}$	86.47 psi	12.41 psi	Pull Back Condition - Option 1
Internal Air and External Fluid 2 = $(P_A + P_a) - P_{DF2}$	85.95 psi	11.89 psi	Pull Back Condition - Option 2
Internal Ballasted and External Fluid 1 = $(P_B + P_a) - P_{DF1}$	102.87 psi	28.82 psi	Pull Back Condition - Option 3
Internal Ballasted and External Fluid 2 = $(P_B + P_a) - P_{DF2}$	102.35 psi	28.29 psi	Pull Back Condition - Option 4
Internal Ballasted and External Water = $(P_B + P_a) - P_W$	106.97 psi	32.92 psi	Long Term Operating Conditions
Internal Air and External Water = $(P_A + P_a) - P_W$	90.57 psi	16.51 psi	Operational Dewatering NO SOIL LOADS

ASSESSMENT UNCONSTRAINED BUCKLING ALONG DRILL PATH BY DIFFERENTIAL PRESSURE

Pipe installation pressure differential does not require ballasting the pipe during pull-back

Pipe may be fully dewatered for operational conditions providing there is no soil loading. Soil loads not assessed.

Engineer to assess any dewatering of the pipe in the future for stability based on actual project conditions and time duration.

TABLE 4

Pg 3 of 3

HDPE PROPERTIES

Champlain Hudson Power Express

Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem

Schenectady County, NY

HDD 73A-74 Conduit #1

NY State Thruway(I-90)

**BRIERLEY
ASSOCIATES**
Limited Liability Company

"Creating Space Underground"

3. ASSESS ULTIMATE PULL STRENGTH (UPS) AND SAFE PULL STRENGTH (SPS)

Source PPI PE Handbook Ch 12 Formula 17 $SPS = \pi \cdot DF \cdot (Ty) \cdot D_o^{2 \cdot ((1/DR) - (1/DR^2))}$

Designed Pull Duration Time =	12 hr	Quantity of pipes, Q =	1
Yield Strength Factor, f_Y =	0.4	Recommended (FS = 2.5)	Pull Temperature, F = 73 deg.
Pull Time factor, f_T =	1	Plexco Engineering Manual Table 3.7	
Design Factor, $DF = f_T \cdot f_Y$ =	0.4	SAFE PULL STRENGTH, SPS =	50,200 lb
Temperature factor, f_{temp} =	1	Ultimate Pull Strength, UPS =	125,499 lb
Temp Corr Tensile Yield, $Ty \cdot f_{temp}$ =	3,500 psi		
Safe Allowable Stress, SAS =	1,400 psi	SAS = $Ty \cdot f_{temp} \cdot DF$	Suggested SSAS = 1,150 psi
Safe Pull Strength, SPS Pipe =	50,200 lb	Using SSAS =	41,235 lb

Short Term Critical Unconstrained Buckling P_{CRR} reduced for pull tension, $P_{CRR} = P_{CR} \cdot f_r$

(ASTM F-1962 EQ. 22)

Pull Duration Time =	12 Hr	P_{CR} =	267.4 psi
SAS =	1,400 psi	Design Depth in DF, H_{MDF} =	0.0 ft
Estimated Maximum Pull Stress, σ_i =	1,150 psi	Design Assumption as Maximum	
$f_r = ((5.57 - (r + 1.09)^2)^{.5}) - 1.09$ =	0.87832		
$r = \sigma_i / 2 \cdot (SSAS)$ =	0.21219	Example from Table T5, σ_i =	488 psi
P_{CRR} =	234.9 psi		
FS =	2.0		
$P_{ACRR} = P_{CRR} / FS$ =	117.4 psi	Allowable Reduced Short Term Buckling pressure during pull	
Internal Ballasted and External Fluid 1 = $(P_B + P_{ACRR}) - P_{DF1}$	96.95 psi	Pull Back Condition - Option 3	OK as >0
Internal Ballasted and External Fluid 2 = $(P_B + P_{ACRR}) - P_{DF2}$	96.42 psi	Pull Back Condition - Option 4	OK as >0

ASSESSMENT OF SAFE PULL STRENGTH ON TENSION REDUCED BUCKLING CAPACITY

ACCEPTABLE Acceptable if differential pressures > 0 for reduced buckling capacity

REFERENCE 1 - Plastic Pipe Institute - Handbook of PE Pipe 2nd Edition

REFERENCE 2 - Plastic Pipe Institute - Handbook of PE Pipe 2nd Edition

Design Factor (fe) to apply to HDB



CHAPTER 6 - TABLE 1-2

REFERENCE 3 - Plexco Engineering Manual Book 3 Ch 3 Table 3.7

Time factor for pull duration, f_T

f_T	Time factor for pull	
1.00	Up to 1 hour pull	1
0.95	Up to 12 hours pull	12
0.91	Up to 24 hours	24

D:\CHPE\HDD73A-74 CIR #1_APC_20240331.xd3\F 1A APCL



NOTES:
1. Geology is interpreted from project data
2. Rod length: 20 feet
3. The error bars are at 20% and represent Drill Fluid low and high density range.
4. Ground surface data obtained from project survey data
5. Subsurface data from Geotechnical Report.

Basis of annular pressure calculations

9.00 in	Pilot Hole Diameter
78.0 pcf	Unit Weight Drill Fluid
200 gal/min	Pump Rate
3.50 in	Drill Rod Diameter
20	Ft per rod
20%	for APC curve

Bore Logs
K178.7A
K178.7B
K178.8
K178.96
B178.9-1
RS-2

Print Date ; 4/1/2024 17:44

BRIERLEY ASSOCIATES
Creating Space Underground
167 S. River Road, Suite 8
Bedford, NH 03110
603.236.5775 (C)

Champlain Hudson Power Express
Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem
Schenectady County, NY
**ANNULAR PRESSURE AND FORMATION
PRESSURE CURVES
HDD 73A-74 Conduit #1
NY State Thruway(I-90)**
Revision 3

FIGURE 1

HORIZONTAL DIRECTIONAL DRILL DESIGN

PROJECT: Champlain Hudson Power Express
Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem
Schenectady County, NY

CROSSING: HDD 73A-74 Conduit #2
NY State Thruway (I-90)

ISSUE: Issued for Construction (IFC)


Contents:

Table 1	DESIGN SUMMARY, ASSUMPTIONS, CONDITIONS
Table 2	DRILL PATH DESIGN CALCULATIONS
Table 3	ANTICIPATED PULLING FORCE - CONSTANT FORCE
Table 4	PLASTIC STRESS
Figure 1	APC AND FPC CURVES AND ASSUMED GEOLOGIC SECTION

Prepared For: Kiewit

Prepared By: Brierley Associates
167 S. River Road, Suite 8
Bedford, NH 03110
603.206.5775 (O)

Project No: 322004-000
Print Date: 1-Apr-2024



Date	ID	DESCRIPTION	BY
10/23/2022	0	Design Submittal	ABL
3/23/2023	1	Issued for Construction	ABL
8/29/2023	2	Profile Alterations	KRF
4/1/2024	3	Plan Revision	NHS

DRILL PATH DESIGN CALCULATIONS

Entry Station	0+00.00	FT	*If no water or mudline then use lower of entry or exit elevation			
Exit Station	20+37.76	FT	Water Surface Elev.* 310.00 ft			
Entry and Exit Design Coordinates & Elevations (Ft) (Note 2)			Mudline Elev.* 310.00 ft			
			Lowest centerline Elev. 273.80 ft			
Entry	629035.3157	1437819.6222	Elevation	325.80 ft		SU
Horizontal Curve PI	629546.9663	1436408.1216				
Exit	629902.4145	1436001.2771	311.30 ft			
Depth to Mudline	15.80 ft	Clearance Depth =	36.20 ft			
Measured Plan Length at ties =	2037.7571 ft					
Coordinate Length =	2037.7571 ft					
OK-HORIZONTAL CURVE						
			Station	Easting	Northing	
Tangent			0+00.00	629035.3157	1437819.6222	
Curve			13+32.80	629489.5177	1436566.606	
Tangent			16+66.09	629657.8784	1436281.172	

SUMMARY HORIZONTAL CURVE CALCULATIONS

	Start			End			Azimuth	Length	Radius	Angle
	Station	Easting	Northing	Station	Easting	Northing				
Tangent	0+00.00	629035.3157	1437819.6222	13+32.80	629489.5177	1436566.6062	E 160.07508 N	1332.80		
Curve	13+32.80	629489.5177	1436566.6062	16+66.09	629657.8784	1436281.1720	E 138.85723 N	333.29	900.00	-21.218 deg.
Tangent	16+66.09	629657.8784	1436281.1720	20+37.76	629902.4145	1436001.2771	E 138.85723 N	371.67		

HORIZONTAL PLAN CALCULATIONS (FT)

Entry Tangent Segment	Horizontal Curve Segment	Exit Tangent Segment
Plan Length, ft. 1332.80	Input Radius, ft. 900.00	Plan Length, ft. 371.67
Entry Azimuth, deg. N 160.07508 E	Curve, deg. -21.218 deg.	Exit Azimuth, deg. N 138.85723 E
Entry Azimuth, rad. 2.79384	Curve, rad. -0.37032	Exit Azimuth, rad. 2.42352
Calculate PCH		
PCH Easting 629489.5177	Chord Length, ft. 331.39	Easting 629902.4145
PCH Northing 1436566.6062	Arc Length, ft. 333.29	Northing 1436001.2771
	Chord Azimuth, deg. 149.4662	
	PI Easting = 629546.9663	
	PI Northing = 1436408.1216	
	PTH Easting = 629657.8784	
	PTH Northing = 1436281.1720	
Cum Plan Length 1332.80	Cum Plan Length 1666.09	Cum Plan Length 2037.75707

Check
Delta
0.0000
OK CALC

Exit Station
20+37.76
OK STA

Pull Geometry

Pipe Entry	Exit	Enter the pipe entry location into the hole: Entry/Exit					Path Length	Curve Radius
	Elevations		Vertical Angle					
Segment	Start	End	Start	End	Δ Angle			
Entry Tangent	311.30 ft	292.03 ft	-10.00 deg	-10.00 deg	0.00 deg	110.97 ft	0.00 ft	
Entry Curve	292.03 ft	273.80 ft	-10.00 deg	0.00 deg	10.00 deg	209.44 ft	1200.00 ft	
Bottom Tangent	273.80 ft	273.80 ft	0.00 deg	0.00 deg	0.00 deg	1349.33 ft	0.00 ft	
Exit Curve	273.80 ft	300.02 ft	0.00 deg	12.00 deg	12.00 deg	251.33 ft	1200.00 ft	
Exit Tangent	300.02 ft	325.80 ft	12.00 deg	12.00 deg	0.00 deg	123.98 ft	0.00 ft	
Total Check =						2045.05 ft	OK	
Compound Curve Assessment								
Start	Vert. Plan	Horiz. Plan						
Entry	370.77	1332.80	No, Horiz > Entry V(Tan+Curve)					
Exit	317.66	371.67	No, Horiz > Entry V(Tan+Curve)					

VERTICLE PATH DESIGN CALCULATIONS (FT)


Entry Tangent Segment 1	Entry Vert. Curve Segment 2	Middle Tangent Segment 3	Exit Vert. Curve Segment 4	Exit Tangent Segment 5
Entry Angle -12.000 deg.	Vertical Radius 1200.00	End Vert Angle 0.000 deg.	Radius 1200.00	Exit Elevation 311.30
	Vert. Curve, deg. 12.000 deg.	Inclined Bottom Tan NO	Angle Change 10.000 deg.	Design Exit Angle 10.00 deg
Calculate Vertical PCV				
Plan Length 121.272 ft	Plan Length 249.494 ft	Plan Length 1,349.33176 ft	Plan Length 208.378 ft	Plan Length 109.282 ft
Rod Length 123.981 ft	Arc Rod Length 251.327 ft	Rod Length 1,349.33176 ft	Arc Rod Length 209.440 ft	Rod Length 110.967 ft
Vertical Depth -25.777 ft	Curve Δ Vert Depth -26.223 ft	Vertical Depth 0.00000 ft	Curve Δ Vert Depth 18.231 ft	Vertical Depth 19.269 ft
Calculate Vertical PTV				
	Lowest Elevation 273.800 ft		Lowest Elevation 273.800 ft	CK Total Cum Depth -14.500 ft
Start Elevation 325.800 ft	Start Elevation 300.023 ft	Start Elevation 273.800 ft	Start Elevation 273.800 ft	Start Elevation 292.031 ft
End Elevation 300.023 ft	End Elevation 273.800 ft	End Elevation 273.800 ft	End Elevation 292.031 ft	Ck Exit Elevation
End Vert Angle -12.000 deg	End Vert Angle 0.000 deg	End Vert Angle 0.000 deg	End Vert Angle 10.000 deg	Prop. Plan Length 2037.75707
SUMMARY VERTICLE CURVE CALCULATIONS				
Start Station 0+00.00	Start Station 1+21.27	Start Station 3+70.77	Start Station 17+20.10	Start Station 19+28.48
PVC Station 1+21.27	PTV Station 3+70.77	PCV Station 17+20.10	PTV Station 19+28.48	Exit Station 20+37.757
Cum Plan Length 121.27	Cum Plan Length 370.77	Cum Plan Length 1720.10 ft	Cum Plan Length 1928.48	Cum Plan Length 2037.76
Cum Rod Length 123.98	Cum Rod Length 375.31	Cum Rod Length 1724.64 ft	Cum Rod Length 1934.08	Cum Rod Length 2045.05
Cum Depth -25.78	Cum Depth -52.00	Cum Depth -52.00 ft	Cum Depth -33.7693	Cum Depth -14.50

Summary of Drill Calculations

Entry to Exit Elevation Change =	-14.50 ft
Minimum Design Elevation =	273.80 ft
Invert Depth below exit =	37.50 ft
Invert Depth below entry =	52.00 ft
Path Length =	2,045.05 ft
Plan Length =	2,037.76 ft
Minimum Plan Length (No Tangent) =	688.43 ft
Entry Angle =	-12.00 deg
Exit Angle =	10.00 deg
Compound Curve at Entry =	NO
Compound Curve at Exit =	NO

NOTES:

- Sign convention for angles - positive (+) angles are counterclockwise. Due East is defined as 0 degrees.
- NAD83 New York State Plane East Zone
- Elevations are referenced to NAVD88 Datum
- All calculation locations represent the center of the drill hole.



	Indicates inputs
	Indicates status on internal design checks
ISSUE:	Issued for Construction (IFC)
Brierley Associates Limited Liability Company	
Champlain Hudson Power Express Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem Schenectady County, NY	
TABLE 2 DRILL PATH DESIGN CALCULATIONS HDD 73A-74 Conduit #2 NY State Thruway (I-90)	
Brierley Associates 167 S. River Road, Suite 8 Bedford, NH 03110	Revision 3
	TBD

Pull Geometry

Lengths (Path)		Angles		Radius, R
L1 =	100.0 ft	Overbend	deg	300.0 ft
L2 =	111.0 ft	$\alpha =$	-10.0 °	-0.1745
L3 =	209.4 ft			1,200.0 ft
L4 =	1349.3 ft	$\chi =$	0.0 °	0.0000
L5 =	251.3 ft			1,200.0 ft
L6 =	124.0 ft	$\beta =$	12.0 °	0.2094
LT =	2145.0 ft			

INPUT: Assumed Friction Factors

$\mu_G =$	0.10	dry + rollers
$\mu_b =$	0.25	drill fluid in hole
$\mu_c =$	0.30	in hole no fluid

INPUT: Assumed Hydrokinetic Drag

$\tau_f =$	0.005 psi	Drill Fluid Shear Stress
------------	-----------	--------------------------

INPUT: Pipe Properties

Material	HDPE	IPS
Safe Pull Max. Stress, σ_{PM}	1,150 psi	PPI Table 1 12hr @ 73Deg F
Pile/Bundle Diam.	10.75	PIPE
Material Density, γ	59.28 pcf	PIPE/BUNDLE
Outside Diameter, D_{OD}	10.75	Pipe or Bundle
Pipe Dry Weight, W_p	15.70 lb/ft	Pipe or Bundle
Min. Wall Thickness, t_m	1.194 in	For design installation pull stress
$DR = D_{OD}/t_{min}$	9	D_{OD} Stress
Avg. Inside Diameter, D_{IA}	8.22 in	Bundle Multiplier F_D
12 Hr Pullback Modulus, E_T	65,000 psi	@T = 73 deg F
Poisson Ratio, μ	0.45	
Ovality Factor, f_o	0.84	2%
Buckling Safety, N	2.5	
Hydrostatic Design Stress, HDS	1,000 psi	HDB/2
Pressure Rating, $PR_{(80F)}$	250 psi	$PR = 2HDSF_T A_F / (DR-1)$ [$F_T=1$]

INPUT: Assumed Fluid Densities/Elevations

Ballast Density	62.4	pcf
Drill Fluid Density	78	pcf
Drill fluid elevation, H_F	310.00 ft	
Ballast Water El., H_W	310.00 ft	
Lowest Invert El., E_{lm}	273.80 ft	

Calculated Pipe and Fluid Properties

Pressure Pipe:	YES
OD Perimeter Length, P	33.77 in
Wall Section Area, A_{WW}	37.70738915
Volume Outside, V_{DO}	0.630 cf/LF
Volume Inside, V_{DI}	0.368 cf/LF
q_d	2.03 lb/ft
ASTM EQ 18: Hydrokinetic, ΔT	0.32 lb/ft

Drill Fluid (unit drag)
Comparison Only @ 8psi


Calculated Buoyant Forces

Pipe	Air Filled	Ballasted
On Ground, w_a/w_{af}	15.70 Lb/LF	38.69 Lb/LF
In Hole with Drill Fluid, w_p/w_{bf}	-33.46 Lb/LF	-10.47 Lb/LF

Pipe Entry Location - Drill

Exit

(schematic, to show definition of variables only)



Calculated Pull Force							ASSESS	
POINT	Pull Force, F_D	Max Tensile Stress, σ_T	ASSESS	Pull Force, F_B	Max Tensile Stress, σ_T	ASSESS	$F_x < SPS$	
	No Ballast		$\sigma_T < \sigma_{PM}$	Ballasted Pipe		$\sigma_T < \sigma_{PM}$	Air	Ballast
A	3,427 lb	193 psi	OK	3,427 lb	193 psi	OK	OK	OK
B	4,257 lb	119 psi	OK	4,429 lb	124 psi	OK	OK	OK
C	5,738 lb	184 psi	OK	5,104 lb	167 psi	OK	OK	OK
D	11,404 lb	318 psi	OK	10,770 lb	300 psi	OK	OK	OK
E	16,126 lb	474 psi	OK	13,307 lb	396 psi	OK	OK	OK
F	17,269 lb	482 psi	OK	13,952 lb	389 psi	OK	OK	OK

ASSESS Pull Restricted Buckling Capacity, $P_{PA} > \Delta P$ invert							$P_{PA} = P_A F_R =$	
							94.15 psi	
							Ballasted	OK
							No Ballast	OK

Maximum tensile stress during pullback = $\sigma_T = (F_T / \pi t_m (D_{OD} - t_m)) + E_T D_{OD} / 2R$

PPI Ch 12 Eq 16

Calculated Material Design Limits For Designed Drill Path

Safe Pull Strength, SPS =	41,235 lb	$SSPS = \sigma_{PM} \pi D_{OD}^2 ((1/DR) - (1/DR'))$
Allowable Short Term Unconstrained Buckling, P_A =	106.97 psi	$P_A = (2E_T / (1 - \mu^2)) ((1/(DR-1))^{3/2} (f_o/N))$
Maximum 12 hour Pull Stress Reduction, F_R =	0.880121965	$F_R = (5.57 - (r + 1.09)^2)^{1/2} - 1.09$
r =	0.209468908	$r = \sigma_T / 2SPS$
Maximum applied pull Stress, σ_T =	482 psi	From Pull Force Calculations
Ballasted Max. Differential Pressure on Pipe, ΔP_B invert =	3.92	psi (-) indicates pipe is pressurized
Unballasted Max. Differential Pressure on Pipe, ΔP_U invert =	19.61	psi (-) indicates pipe is pressurized

Calculated Drill Hole Diameter Assumed for Calculations

$D_H =$	18
---------	----

$D_O < 8"$ Use $D_H = D_O + 4"$; $8" < D_O < 24"$ Use $D_H = 1.5 * D_O$; $D_O > 24"$ Use $D_H = D_O + 12"$

NOTES: 1 - Calculations were done in general accordance with ASTM F-1962 as modified to account for invert tangent section, independent vertical curves, and fluid drag. ASTM applies hydrokinetic pressure as shear per unit pipe length requiring a back calculation to determine actual pull force based on average pipe area.

ISSUE: Issued for Construction (IFC)

BRIERLEY ASSOCIATES Limited Liability Company "Creating Space Underground" Briery Associates 167 S. River Road, Suite 8 Bedford, NH 03110	Champlain Hudson Power Express Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem Schenectady County, NY
	TABLE 3 - PULL ASSESSMENT ANTICIPATED PULLING FORCE - HDPE PULL HDD 73A-74 Conduit #2 NY State Thruway (I-90)

Revision 3

TBD

TABLE 4

Pg 1 of 3

HDPE PROPERTIES

Champlain Hudson Power Express

Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem

Schenectady County, NY

HDD 73A-74 Conduit #2

NY State Thruway (I-90)

INPUTS

Pipe Material Properties

Sources: ASTM D3350 and Plastic Pipe Institute Publications and as referenced

Design Working Pressure, P _{WORK}	250 psi	Test Pressure, P _{TEST}	0 psig	At high point
Quantity of Pipes in Hole, Q =	1			
Pipe Material	PE4710	INPUT RESIN MATERIAL: PE3408, PE3608, PE4710		
ASTM D3350 Cell Classification	445574C	Design resin with minimum PENT test of 10,000 hours		
Standard Dimension	10			
Pipe measurement standard	IPS	IPS "Iron Pipe Size" of DIPS "Ductile Iron Pipe Size"		
DR = OD/Minimum Wall	9			
Outside Diameter, D _o =	10.750 in	Standard Manufacturer's Data Sheets		
Avg. Inside Diameter, D _i =	8.219 in	Standard Manufacturer's Data Sheets		
Minimum Wall, t _{min} =	1.194 in	Standard Manufacturer's Data Sheets		
Wall Section Area, A _W =	35.85681985	A _W = π*((D _o /2) ² -((D _o -2t)/2) ²)		
Unit OD Surface Area, in ² /LF, A _{OD} =	405.27 in ² /LF	A _{OD} = 12*π*D _{OD}		
Unit Outside Volume, V _{Do} =	0.630 cf/LF	V _{Do} = π*(D _o /2) ² /144		
Unit Inside Volume, V _{Di} =	0.368 cf/LF	V _{Di} = π*(D _i /2) ² /144		
HDB =	1,600 psi	Based on PPI Publication TR-4/2015 and ASTM 2837		
Design Factor for HDB, DF =	0.625	Based on PPI PE Handbook 2nd ED Chapter 5		
Hydrostatic Design Stress, HDS =	1000 psi	HDS = HDB*DF		
Environmental Factor, Af _e =	1	Reference 2: Use for pressure rating only		
Density =	59.28 pcf	1.410 g/cc	Average from WL Plastics WL122 for PE4710	
Weight Dry, W =	15.68	Lb/LF		
Tensile Yield, Ty psi =	3,500 psi	@73°F	Minimum from ASTM D3350 determined by ASTM D638	
Load Duration	Short Term	Long Term		
Duration Time	10 hours	50 yrs		
Design Temperature, °F	73 deg F	73 deg F	Assumed	
Design Ovality, %	2%	4%	See Sheets 4 of 5 for design ovality	
Factor of Safety, FS =	2.5	2.5	Industry Practice	
Modulus for given load duration, E =	65,000 psi	28,000 psi	Based on PPI Handbook Ch. 3 and WL Plastics WL118-0314	
Poisson Ratio, ν =	0.45	0.45	WL118: Use 0.35 if load duration is less than 12 hours	
Ovality factor f _o =	0.84	0.6	Reference 1: Based on Selected Design Ovality	
Temperature factor, f _t =	1.00	1.00	Source: WL Plastics WL118	

Project Fluids

Fluids	Pipe Internal Ballast	Expected External Fluid	Heavy External Fluid	Buoyant forces	
	Fresh Water	Drill Fluid 1	Drill Fluid 2	Dry Weight Pipe on ground, W_P	From MFG. Data Sheet
	γ_{INT}	γ_{EXT1}	γ_{EXT2}	Internal Ballast Weight, W_B	$W_B = V_{Di} * \gamma_{INT}$
Density, γ	62.4	78	80	Expected Displaced Fluid Weight, W_{D1}	$W_{D1} = V_{Do} * \gamma_{EXT1}$
	Buoyant Unballasted Fluid 1, B_{B1}	-33.48 lb/ft	$W_P - W_{D1}$	Heavy Displaced Fluid Weight, W_{D2}	$W_{D2} = V_{Do} * \gamma_{EXT2}$
	Buoyant Unballasted Fluid 2, B_{B2}	-34.74 lb/ft	$W_P - W_{D2}$		
	Ballasted on ground, B_G	38.67 lb/ft	$W_P + W_B$		
	Buoyant Ballasted in Fluid 1, BB_{B1}	-10.49 lb/ft	$BG - W_{D1}$		
	Buoyant Ballasted in Fluid 2, BB_{B2}	-11.75 lb/ft	$BG - W_{D2}$		

TABLE 4

Pg 2 of 3

HDPE PROPERTIES

Champlain Hudson Power Express

Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem

Schenectady County, NY

HDD 73A-74 Conduit #2

NY State Thruway (I-90)

1. ASSESS PIPE PRESSURE RATING

Failure mode: Short term = burst; Long term = slow crack growth

Short Term (<10 hours)

Design Temperature, °F =	73 deg F	
Ultimate Internal Pressure, P_U =	875 psi	$P_U = 2 \cdot T_y \cdot f_t / (DR-1)$
Allowable Internal Pressure, P_A =	400 psi	$P_A = 2 \cdot HDB \cdot f_t / (DR-1)$

ASSESSMENT TEST PRESSURE

OK

OK if $P_A \geq P_{TEST}$

Long Term Design for operating conditions

Design Temperature, °F =	73 deg F	
Pressure Rating, PR =	250 psi	$PR = 2 \cdot HDS \cdot f_t \cdot A_f / (DR-1)$
Maximum Occasional Surge, P_{OS} =	500 psi	$P_{OS} = 2 \cdot PR$
Maximum Reoccurring Surge, P_{RS} =	375 psi	$P_{RS} = 1.5 \cdot PR$

ASSESSMENT PRESSURE RATING

OK

OK if $PR \geq P_{WORK}$

2. ASSESS PIPE UNCONSTRAINED BUCKLING CAPACITY FOR CONSTRUCTION PRESSURES

CALCULATE: Unconstrained Buckling Capacity of pipe

Unconstrained buckling ASTM F1962 EQ 5

$$\text{Critical Pressure, } P_{CR} = f_o \cdot [2 \cdot E / (1 - \nu^2)] \cdot [(1 / (DR-1))^3]$$

	Short Term	Long Term
Design Temperature, F =	73 deg F	73 deg F
P_{CR} =	267.4 psi	82.3 psi
$P_a = P_{CR} / FS$	107.0 psi	32.9 psi

CALCULATE: internal and external pressure for deepest pipe invert depth and construction conditions

Critical unconstrained buckling pressure is at the pipe invert

Max. Depth to Invert Ballast depth to invert, H_B Drill Fluid depth to invert, H_{DF} Pipe Invert Internal Pressure, P_i

Air Ballast, P_A	0.00 psi
Full Ballast, $P_B = \gamma_{INT} \cdot (H_B + D_o / 24) / 144$	16.44 psi

Pipe Invert External Pressure, P_E

Drill Fluid 1, $P_{DF1} = \gamma_{EXT1} \cdot (H_{MDF} + D_o / 24) / 144$	20.56 psi
Drill Fluid 2, $P_{DF2} = \gamma_{EXT2} \cdot (H_{MDF} + D_o / 24) / 144$	21.08 psi
Water, $P_W = \gamma_{INT} \cdot (H_{DF} + D_o / 24) / 144$	16.44 psi

Unconstrained buckling occurs when DIFFERENTIAL PRESSURE between the inside pressure plus pipe capacity is less than the outside pressure. $(P_i + P_a) - P_E \leq 0$

Differential Pressures

	Short Term	Long Term	
Internal Air and External Fluid 1 = $(P_A + P_a) - P_{DF1}$	86.42 psi	12.36 psi	Pull Back Condition - Option 1
Internal Air and External Fluid 2 = $(P_A + P_a) - P_{DF2}$	85.89 psi	11.83 psi	Pull Back Condition - Option 2
Internal Ballasted and External Fluid 1 = $(P_B + P_a) - P_{DF1}$	102.86 psi	28.80 psi	Pull Back Condition - Option 3
Internal Ballasted and External Fluid 2 = $(P_B + P_a) - P_{DF2}$	102.34 psi	28.28 psi	Pull Back Condition - Option 4
Internal Ballasted and External Water = $(P_B + P_a) - P_W$	106.97 psi	32.92 psi	Long Term Operating Conditions
Internal Air and External Water = $(P_A + P_a) - P_W$	90.53 psi	16.47 psi	Operational Dewatering NO SOIL LOADS

ASSESSMENT UNCONSTRAINED BUCKLING ALONG DRILL PATH BY DIFFERENTIAL PRESSURE

Pipe installation pressure differential does not require ballasting the pipe during pull-back

Pipe may be fully dewatered for operational conditions providing there is no soil loading. Soil loads not assessed.

Engineer to assess any dewatering of the pipe in the future for stability based on actual project conditions and time duration.

TABLE 4

Pg 3 of 3

HDPE PROPERTIES

Champlain Hudson Power Express

Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem

Schenectady County, NY

HDD 73A-74 Conduit #2

NY State Thruway (I-90)

3. ASSESS ULTIMATE PULL STRENGTH (UPS) AND SAFE PULL STRENGTH (SPS)Source PPI PE Handbook Ch 12 Formula 17 $SPS = \pi * DF * (Ty) * D_o^{2*}((1/DR)-(1/DR^2))$

Designed Pull Duration Time =	12 hr	Quantity of pipes, Q =	1
Yield Strength Factor, f_Y =	0.4	Recommended (FS = 2.5)	Pull Temperature, F = 73 deg.
Pull Time factor, f_T =	1	Plexco Engineering Manual Table 3.7	
Design Factor, $DF = f_T * f_Y$ =	0.4	SAFE PULL STRENGTH, SPS =	50,200 lb
Temperature factor, f_{temp} =	1	Ultimate Pull Strength, UPS =	125,499 lb
Temp Corr Tensile Yield, $Ty * f_{temp}$ =	3,500 psi		
Safe Allowable Stress, SAS =	1,400 psi	$SAS = Ty * f_{temp} * DF$	Suggested SSAS = 1,150 psi
Safe Pull Strength, SPS Pipe =	50,200 lb	Using SSAS =	41,235 lb

Short Term Critical Unconstrained Buckling P_{CRR} reduced for pull tension, $P_{CRR} = P_{CR} * f_r$

(ASTM F-1962 EQ. 22)

Pull Duration Time =	12 Hr	$P_{CR} =$	267.4 psi
SAS =	1,400 psi	Design Depth in DF, $H_{MDF} =$	0.0 ft
Estimated Maximum Pull Stress, $\sigma_i =$	1,150 psi	Design Assumption as Maximum	
$f_r = ((5.57 - (r + 1.09)^2)^{.5}) - 1.09 =$	0.88012		
$r = \sigma_i / 2 * (SSAS) =$	0.20947	Example from Table T5, $\sigma_i =$	482 psi
$P_{CRR} =$	235.4 psi		
FS =	2.0		
$P_{ACRR} = P_{CRR} / FS =$	117.7 psi	Allowable Reduced Short Term Buckling pressure during pull	
Internal Ballasted and External Fluid 1 = $(P_B + P_{ACRR}) - P_{DF1}$	97.13 psi	Pull Back Condition - Option 3	OK as >0
Internal Ballasted and External Fluid 2 = $(P_B + P_{ACRR}) - P_{DF2}$	96.61 psi	Pull Back Condition - Option 4	OK as >0

ASSESSMENT OF SAFE PULL STRENGTH ON TENSION REDUCED BUCKLING CAPACITY**ACCEPTIBLE** Acceptible if differential pressures > 0 for reduced buckling capacity

REFERENCE 1 - Plastic Pipe Institute - Handbook of PE Pipe 2nd Edition

REFERENCE 2 - Plastic Pipe Institute - Handbook of PE Pipe 2nd Edition



Design Factor (fe) to apply to HDB

CHAPTER 6 - TABLE 1-2

REFERENCE 3 - Plexco Engineering Manual Book 3 Ch 3 Table 3.7

Time factor for pull duration, f_T

f_T	Time factor for pull	
1.00	Up to 1 hour pull	1
0.95	Up tp 12 hours pull	12
0.91	Up to 24 hours	24



Notes:

1. Geology is interpreted from project data
2. Rod length: 20 feet
3. The error bars are at 20% and represent Drill Fluid low and high density range.
4. Ground surface data obtained from project survey data
5. Subsurface data from Geotechnical Report.

Basis of annular pressure calculations

9.00 in	Pilot Hole Diameter
78.0 pcf	Unit Weight Drill Fluid
200 gal/min	Pump Rate
3.50 in	Drill Rod Diameter
20	Ft per rod
20%	for APC curve

Bore Logs

K178.7A
K178.7B
K178.8
K178.96
B178.9-1
RS-2

Print Date ; 4/1/2024 17:54

ISSUED: Issued for Construction (IFC)

BRIERLEY ASSOCIATES
Creating Space Underground

167 S. River Road, Suite 8
Bedford, NH 03110
603.266.5775 (C)

Champlain Hudson Power Express
Segment 8 (Pkg. 5A) - CSX: Rotterdam to Bethlehem
Schenectady County, NY

**ANNULAR PRESSURE AND FORMATION
PRESSURE CURVES**
HDD 73A-74 Conduit #2
NY State Thruway (I-90)

Revision 3

FIGURE 1